TISHMAN REALTY & CONSTRUCTION CO., INC. (AGENT) F-WERNEKE

WORLD TRADE CENTER

WTCI-289-P

OFFICE CORRESPONDENCE

TO: MR. F. WERNEKE, P/A DATE: 9/26/69

FROM: MR. M. GERSTMAN

SUBJECT: WTC 113.00 - SPRAY-ON FIREPROOFING - THICKNESS TO BE SPRAYED ON STEEL

ENCLOSED FIND COPIES OF MARIO & DIBONO'S LETTERS OF SEPT. 15, 1969 AND SEPT. 18, 1969 IN WHICH THEY SUBMIT FOR APPROVAL A SCHEDULE OF SPRAY-ON THICKNESS TO BE SPRAYED ON STEEL.

PLEASE NOTE THAT THEY HAVE EXCLUDED TAMPING OR SHAPING. THE SPECIFICATION MAKES NO REFERENCE TO THESE ITEMS. SHAPING OF THE FIREPROOFING SHOULD BE DONE IN AREAS EXPOSED TO VIEW. CAFCO CATALOG STATES THAT WITH THE USE OF BLAZE-SHIELD TYPE D, TAMPING IS NOT REQUIRED.

PLEASE ADVISE.

DM/MG/EB

CC-MONTI, LINN, BORLAND, BROWN, P/A W/ATT.

CC-MR. JOS. SOLOMON (EMERY ROTH) W/ATT.

File 113.00

See letter
R&R to DiBono
10/30/69

PLAINTIFF'S EXHIBIT PX-531

THE PORT OF NEW YORK AUTHORITY
OFFICE OF CONSTRUCTION
RECEIVED
SEP 26 1969
PLANNING & CONSTRUCTION DIVISION

TISHMAN REALTY & CONSTRUCTION CO., INC. (AGENT)

(APPROVALS)

WORLD TRADE CENTER

0011910

OFFICE CORRESPONDENCE

TO: MR. F. WERNEKE, P/A

DATE: 9/26/69

FROM: MR. M. GERSTMAN

SUBJECT: WTC 113.00 - SPRAY-ON FIREPROOFING - THICKNESS TO BE SPRAYED ON STEEL

ENCLOSED FIND COPIES OF MARIO & DIBONO'S LETTERS OF SEPT. 15, 1969 AND SEPT. 18, 1969 IN WHICH THEY SUBMIT FOR APPROVAL A SCHEDULE OF SPRAY-ON THICKNESS TO BE SPRAYED ON STEEL.

PLEASE NOTE THAT THEY HAVE EXCLUDED TAMPING OR SHAPING. THE SPECIFICATION MAKES NO REFERENCE TO THESE ITEMS. SHAPING OF THE FIREPROOFING SHOULD BE DONE IN AREAS EXPOSED TO VIEW. CAFCO CATALOG STATES THAT WITH THE USE OF BLAZE-SHIELD TYPE D, TAMPING IS NOT REQUIRED.

PLEASE ADVISE.

DM/MG/EB

CC-MONTI, LINN, BORLAND, BROWN, P/A W/ATT.

CC-MR. JOS. SOLOMON (EMERY ROTH) W/ATT.

DTL

5732-5 22-3-4

Mario & Di Bono

Plastering Co., Inc.

136 LIBERTY STREET NEW YORK, N. Y. 10006

September 15, 1969

Mr. Milt Gerstman
Tishman Realty & Construction Co., Inc.
30 Church Street
New York, New York

RE: Fireproofing thickness' to be sprayed on steel

Dear Mr. Gerstman:

This list is being submitted for your approval.

1. Beams throughout buildings - 1/2 inch. No tamping or shaping of Cafco type D. 4 Hr. = 1/2" Beams

2. Columns 1 3/16 inches. No tamping or shaping of Cafco type D. 1 5/16 for HW 12 or greater. 2 3/16

3. Elevator columns - 1 inch total including overspray. No tamping or shaping of Cafco type D.

4. Bar joist - 1 inch overall thickness. No tamping or shaping of Cafco type D. 4 Hr. - 1" Joist

Very truly yours,

MARIO & DI BONO PLASTERING CO., INC.

Louis Di Bono

LD/cz

TISHMAN REALTY & CONST. CO., INC.

SEP 15 1969

732-5222-3-4

Mario & Di Bono

Plastering Co., Inc.

136 LIBERTY STREET NEW YORK, N. Y. 10006

September 18, 1969

Mr. Milt Gerstman
Tishman Realty & Construction Co., Inc.
30 Church Street
New York, New York

RE: Fireproofing thickness' to be sprayed on steel

Dear Mr. Gerstman:

In regard to our letter dated September 15, 1969 concerning the thickness of fireproofing material, please add the following paragraph:

5. All beams in MER rooms and utility rooms will be 1/2 inch thickness with overspray. No tamping or shaping of Cafco type D.

Very truly yours,

MARIO & DI BONO PLASTERING CO., INC.

Louis DiBono

LD/cz

TISHMAN REALTY & CONST. CO., INC.

SEP 22 1969

732-5222-3-4

0011906

Mario & Di Bono
Plastering Co., Inc.
136 LIBERTY STREET NEW YORK, N. Y. 10006

September 18, 1969

Mr. Milt Gerstman
Tishman Realty & Construction Co., Inc.
30 Church Street
New York, New York

RE: Fireproofing thickness' to be sprayed on steel

Dear Mr. Gerstman:

In regard to our letter dated September 15, 1969 concerning the thickness of fireproofing material, please add the following paragraph:

5. All beams in MER rooms and utility rooms will be 1/2 inch thickness with overspray. No tamping or shaping of Cafco type D.

Very truly yours,

MARIO & DI BONO PLASTERING CO., INC.

Louis DiBono

LD/cz

TISHMAN REALTY & CONST. CO., INC.
SEP 22 1969
DHL